



1411 NE Todd George Road | Lee's Summit, MO 64086 | 816.703-7098 | www.HgCons.com

May 27, 2021

Cobey Creek, Phase 1, Lot 30- No MBOE Requirement

Gene Williams, PE
Senior Staff Engineer
City of Lee's Summit

Based on our analysis for the 100 year HGL in the storm system that might affect Lot 30, we found that the level stays below the minimum 6 " below the field inlet throat openings and therefore requires no establishment of the MBOE for the house to be built on Lot 30 per the storm system.

Regards,

Kevin Sterrett, PE,PLS
Project Engineer

