

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203513
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Partial	Thursday, May 27, 2021

Informational:	
1	Miscellaneous Correction
	AREAS APPROVED:
	IN WALL FOR BATHROOMS COMPLETE
	CHECK CLEARANCE SUSPENDED TRANSFORMER ABOVE SERVICE PANEL AT
	FUTURE WATER HEATER
	- 2ND FLOOR PRESS BOXES -

Comments: