

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202544
Address: 1509 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Friday, May 28, 2021

Corrective Action Required:

1	Misc	-Resolve outstanding inspection fee(s) before final c of o -Final grade and sod -Guardrail at front porch -Splash blocks at all downspout and sump pump locations -Handrail height at garage stairs must be between 34"-38"
---	------	---

Comments: