

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202672
Address: 606 NE LONE HILL DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, May 28, 2021

Corrective Action Required:

1	Misc	**EROSION CONTROL SHALL BE REPAIRED ALONG THE STREET. MUD RUNOFF MUST BE CLEANED OFF THE STREET IMMEDIATELY -Final grade, sod, downspout and sump pump extensions -Install window well ladder -Paint gas service piping to protect against corrosion -Nail all holes at rear patio Simpson post support bases -Check rear patio roof for damage -Replace broken furnace&WH interconnecting fitting **screw the connection -Provide AFCI protection for all outlets required per NEC 210.12 (entry, kitchen A recept)
---	------	--

Comments: