

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202913
Address: 132 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Failed	Friday, May 28, 2021

Corrective Action Required:

1	Misc	-PFH detail on S-2.0 requires 3 bottom plates with 3" oc fastening per plate -Two rows of 16D sinker nails 3" oc at braced wall panel top plates per plan, see section view of detail -3" oc fastening at wall top plate per detail
---	------	---

Corrective Action Required:

2	Misc	City approved plans required to be on site for inspections
---	------	--

Comments: