

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211884
Address: 350 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Morris	Partial	Friday, May 28, 2021

Informational:
1 Misc partial approval of rated assembly between occupancies. screw pattern approved on 340 side of assembly except in front office area where window was removed. ok to rock 350 side of assembly and complete fireblocking as discussed onsite with contractor.

Comments: