

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211755
Address: 4541 NE SENECA TER, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Tuesday, June 01, 2021

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	-EROSION CONTROL ALONG THE STREET SHALL BE REPAIRED. -STREET SHALL BE CLEANED UP IMMEDIATELY NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.
---	---	--

Comments: