

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210347
Address: 1221 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Tuesday, June 01, 2021

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	-EROSION CONTROL REQUIRED ON THE DOWNWARD SLOPE SIDE OF THE LOT, THE EAST AND AROUND THE PILE OF DIRT . -STREET SHALL BE CLEANED UP IMMEDIATELY
---	---	---

NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS
INSTALLED AND IN COMPLIANCE.

Comments: