

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210367
Address: 2108 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, June 01, 2021

Corrective Action Required:

1	Misc	PORTAL FRAME, PORCH, COVERED DECK ONLY GARAGE PFH PORTAL FRAME NAIL SHEATHING ABOVE OVERHEAD DOOR SOLID BLOCK SHEATHING BREAKS ABOVE OVERHEAD DOOR FASTEN TOP PLATE TO HEADER WITH 2 ROWS 16D SINKERSAT 3" OC PROVIDE TENSION STRAPS AT PFH PORTAL FRAME PER PLAN REAR DECK PROVIDE H 2.5S PER PLAN, PROVIDE TJC37 HANGERS PER PLAN FRONT PORCH OK TO COVER
---	------	--

Comments: