CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202825

Address: 1209 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Tuesday, June 01, 2021

Residential

Corrective Action Required:

1 Misc -Rear lot landscape shall be compliant with city ordinance. See plot plan for

details. Trees shall have min size per detail

-Final grade, sod, downspout and sump pump extensions. Regrade the rear of

lot. There is a 20 ft of swale with ponding water

-Make sure that the sewer tracer wire and port are installed and available at

grade level

-Install spark rings flushed to wall finish for receptacle boxes in master

bedroom

-Screw the exterior door embedded metal brace into studs with 3" screws

-Install kitchen hood. Install breaker lock at panel

-Install box extensions for switch & receptacle boxes recessed more than 1/4"

behind wet bar countertop backsplash

Comments: