

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20212580
Address: 529 SE 2ND ST, Unit:B, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Tuesday, June 01, 2021

Corrective Action Required:

1	Misc	PROVIDE ADDRESS BACK DOOR (UNIT B) PROVIDE 18" VERTICAL GRAB BAR RESTROOM PROVIDE DISCHARGE PIPE TERMINATE NOT MORE THAN 6' ABOVE AND NOT LESS THAN TWO TIMES THE DISCHARGE PIPE DIAMETER ABOVE THE FLOOR
---	------	--

Comments: