

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210529  
Address: 3219 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	John Morris	Failed	Wednesday, June 02, 2021

Corrective Action Required:

1	Misc	-footing/column pad depths not per plan -retaining wall in SE corner not on approved house plans or approved plot plan -no foundation pier documentation on file and no third party inspection report on file
---	------	---

Comments: