

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211697
Address: 4737 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed	Wednesday, June 02, 2021

Corrective Action Required:

1	Misc	-AT SOUTH BATHROOM, CANNOT VENT TWO TRAPS AT ONCE. VENT THE SHOWER TRAP FIRST TO WET-VENT THE TOILET
---	------	--

Comments: