



June 3, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field Issue of LVL header for engineered braced wall panel in great room for Lot #14 Woodside Ridge – 2025 NW Ashurst Dr. Lee's Summit, MO 64081 – Permit # PRRES20204780

This letter addresses the continuous LVL header in great room for engineered braced wall panels for Lot #14 Woodside Ridge.

- It is structurally acceptable to install (2) 1-3/4" x 11-1/4" LVL header continuous to jack studs at ends of windows with (2) CS-16 straps at studs in between windows at great room.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a light blue horizontal line.

Bradley Huxol, PE

