

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201498
Address: 140 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-------------|----------|-----------------------|
| Occupancy Inspection - Codes Residential | John Morris | Failed | Friday, June 04, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Seal Exterior Penetrations -AFCI Circuits 9, 11, 13, 19, 10, 18, 23 -GFCI and AFCI circuits 10 & 16 -Provide sprinkler signage at water shut off |
|---|------|--|

Comments: