

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202669  
Address: 2330 SW OLD PORT RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	John Morris	Failed	Friday, June 04, 2021

Informational:

1	Misc	portal frame approved
---	------	-----------------------

Corrective Action Required:

2	Miscellaneous Correction	-Complete nailing pattern at exterior sheathing. Minimum 6" edge & 12" field
---	--------------------------	--

Ok to insulate and rock. Do not paint exterior until exterior sheathing fastening correction is resolved

**Comments:**