

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20193055  
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Hydrostatic Test</b>	John Jackson	Passed	Monday, July 06, 2020

Informational:

1	Misc	On Thursday, 7-02-2020. Sub Contractor CG Excavating Completed the pressure test for the Fire Line. 200 lbs. of pressure was introduced into the 8" Water main. It held pressure for 2 hours and did not lose any pressure passing testing of the fire line.
---	------	--

**Comments:**