

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204527  
Address: 1519 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:    | Outcome: | Date:                 |
|----------------------------|---------------|----------|-----------------------|
| <b>Driveway Inspection</b> | Nick Lightner | Partial  | Friday, June 04, 2021 |

Informational:  
1 Misc 6/4/21- 6in depth, told Bob to place expansion on the curb line, tool or expansion on the 11ft easement line and to use KCCMB Mix. Driveway is good to pour.

**Comments:**