

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193055
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:
DE - Water Line - Hydrostatic Test John Jackson Passed Monday, July 06, 2020

Informational:
1 Misc On Thursday, 7-02-2020. Sub Contractor CG Excavating Completed the pressure test for the Fire Line. 200 lbs. of pressure was introduced into the 8" Water main. It held pressure for 2 hours and did not lose any pressure passing testing of the fire line.

Informational:
2 Misc On Wed, 8-26-2020. The contractor preformed hydrostatic pressure test on 4" private waterline. 150lbs of air pressure was introduced in the line for 2 hours. Passed pressure test.

Comments: