

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203170
Address: 1032 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Partial	Friday, June 04, 2021

Corrective Action Required:

1	Misc	Forms were placed, but out of tolerance. Aggregate was present, but not at the correct thickness. RP 5-12-21
---	------	--

Informational:

2	Misc	Forms were placed and aggregate was present and compacted. RP 6-4-21
---	------	--

Comments: