CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203845

Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Footing Inspection - Robb Popp Partial Friday, June 04, 2021

Commercial

Informational:

1 THE FOLLOWING AREA "S" (NORTH ATHLETIC COMPLEX)

AREAS ARE

APPROVED -UFER AT SOUTHWEST CORNER OF BUILDING

-FOOTINGS FOR BUILDING AND SCREEN WALL COMPLETE

-FOOTING FOR RADIUS RETAINING WALL NORTH OF COMPLEX-

-RADIUS FOUNDATION WALL COMPLETE

BASEBALL DIAMONDS:

-SOUTHEAST, NORTHWEST HOME AND VISITORS DUGOUTS

Comments: