

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204988
Address: 310 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Partial	Friday, June 04, 2021

Corrective Action Required:

1	Misc	Forms were placed and aggregate was present, but not at the required thickness. RP 6-4-21
---	------	---

Informational:

2	Misc	Crew came back and dug out the approach and added 4 inches of aggregate. RP 6-4-21
---	------	--

Comments: