

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210103
Address: 2100 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Retaining Wall Inspection	Khanh Nguyen	Partial	Friday, June 04, 2021

Informational:
1 Misc Contractor (BC Hardscapes Landscape Construction) constructing Retaining Wall. Detailed inspection will be done by Third party Inspector (PSI).

Comments: