



PLAN REVIEW CONDITIONS

June 07, 2021

IDesign Drafting
1499 Bircham Rd
Louisville, KY 40245

Permit No: PRCOM20212613
Project Title: BUFF CITY SOAP
Project Address: 2050 NW LOWENSTEIN DR, Unit:C, LEES SUMMIT, MO 64081
Parcel Number: 51800042200000000
Location: STREETS OF WEST PRYOR LOTS 1-14 & TRACTS A-D---LOT 3
Type of Work: NEW TENANT FINISH
Occupancy Group: MERCANTILE
Description: TENANT FINISH FOR SALES OF SOAP PRODUCTS

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved

Building Plan Review

Reviewed By: Joe Frogge

Pending

1. 2018 IBC 602.1 General. Buildings and structures erected or to be erected, altered or extended in height or area shall be classified in one of the five construction types defined in Sections 602.2 through 602.5. the building elements shall have a fire-resistance rating not less than that specified in Table 601 and exterior walls shall have a fire resistance rating not less than that specified in Table 602. Where required to have a fire-resistance rating by Table 601, building elements shall comply with the applicable provisions of Section 703.2. The protection for openings, ducts and air transfer openings in building elements shall not be required unless required by other provisions of this code.

Action required: Update Building Code Design Data to show correct construction type which is 5B.

2. Unable to determine pipe materials.

Action required: Provide pipe material schedule that includes waste, vent, and NG.

3. Electrical power riser diagram doesn't match diagram provided at shell building construction.

Action required: Coordinate electric service design with existing conditions and update new diagram accordingly.

4. This structure has been assigned one address. All suites/apartments shall be assigned an address by the owner which can be numeric, alphabetic or a combination of both. If the building has multiple stories the suite/apartment number shall start with a number representing the floor on which the unit is located.

Action required: Provide verification that this tenant will be suite C as submitted. Shell construction indicates 3 suites with the middle suite being B. Designs provided look like this is the middle suite.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.