

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211895
Address: 4733 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|------------------------|--------------|----------|------------------------|
| Erosion Control | Khanh Nguyen | Failed | Tuesday, June 08, 2021 |

Corrective Action Required:

| | | |
|---|---|---|
| 1 | DCM1 ESC REQUIRED NO FURTHER INSP | -MIN 3/4" GRAVEL FILTER EROSION CONTROL REQUIRED AT LOT ENTRANCE. -RESTORE SILT FENCE ALONG THE STREET, SPREAD OUT GRAVEL FILTER AT LOT ENTRANCE, AND CLEAN UP THE STREET |
|---|---|---|

NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS
INSTALLED AND IN COMPLIANCE.

Comments: