

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211353
Address: 4820 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Tuesday, June 08, 2021

Corrective Action Required:	
1	DCM2 ESC DEFICIENT INSTALLATION
	DEFICIENT EROSION CONTROL INSTALLATION. SHALL PROVIDE GRAVEL FILTER AT LOT ENTRANCE, RESTORE EROSION CONTROL ALONG THE STREET, AND CLEAN UP THE STREET ON BOTH SIDES

NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.

Comments: