

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203927
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Morris	Partial	Tuesday, June 08, 2021

Informational:

1	Misc	-ROTISSERIE AREA- -Light test approved -first and second layers of grease duct wrap approved -HIBACHI GRILL- -light test approved -first and second layers of grease duct wrap approved -PIZZA OVEN- -light test approved -first and second layer of grease duct wrap approved
---	------	--

Comments: