

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204527
Address: 1519 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Nick Lightner	Passed	Tuesday, June 08, 2021

Informational:
1 Misc 6/4/21- 6in depth, told Bob to place expansion on the curb line, tool or expansion on the 11ft easement line and to use KCCMB Mix. Driveway is good to pour.

Informational:
2 Misc 6/8/21- Driveway has been poured, expansion joint on the curb and 11ft easement.

Comments: