

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204543
Address: 103 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Wednesday, June 09, 2021

Corrective Action Required:

1 Misc

Maintain silt fence until sod complete
Sidewalk inspection pending
Provide final grade, sod, splash blocks
Provide irrigation permit
Provide blocking at cantilever near main service panel
Basement handrail height measured vertically from the slopes plane adjoining the stair nosing shall be not less than 34" and not more than 38" R311.7.8.1 2018 IRC

Comments: