

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204075
Address: 1920 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|--------------------------|
| Gas Service Inspection - Residential | Mark Harding | Passed | Wednesday, June 09, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | Pressure test gas piping minimum 10 psi for 15 minutes |
|---|------|--|

Comments: