

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204752  
Address: 2045 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Wednesday, June 09, 2021

Informational:  
1 Misc

PARTIAL INSPECTION  
GARAGE PORTAL FRAMING ,DECK CEILING ,PORCH CEILING

Fasten top plate to header with two rows of 16D sinkers at 3" OC per plan @ PFH portal frame  
Solid block sheathing breaks above LVL  
Provide LUS24 hangers truss H01/JO3 @ front porch per plan  
Covered deck ok to cover

**Comments:**