

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203927  
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Mark Harding	Failed	Wednesday, June 09, 2021

Informational:	
1 Misc	See onsite copy of city approved plans for dates and sections approved
Corrective Action Required:	
2 Misc	In wall- ok to one side Pharmacy and pateint rooms without plumbing. As discussed with Thomas and framer. plumbing protectio plates needed where required. electrical incomplete at checking and lab rooms.

**Comments:**