

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202304
Address: 1519 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Wednesday, June 09, 2021

Corrective Action Required:

1	Misc	-driveway inspection required -contact development services to schedule -As graded plot plan required, submit for review -Install cover plate kitchen countertop receptacle -Hot water heater must be operational -Remove pressure gauge from gas line
---	------	--

Comments: