

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202961
Address: 2366 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Wednesday, June 09, 2021

Corrective Action Required:

1	Misc	-Maintenance of erosion control methods is required until sod is in place -Final grade and sod -Downspouts to discharge minimum 36 inches from foundation -complete kitchen island plumbing -Remove pressure gauge from gas piping at furnace -Remove debris and provide cap at open DWV in basement, by furnace
---	------	---

Comments: