CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201772
Address: 3202 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Partial	Wednesday, June 09, 2021

Informational:

1	Misc	Forms were placed and aggregate was present and compacted. The contractor (Mead Concrete) formed up sidewalks on both Pergola Park and Grandstand Circle. Plot plans show no sidewalk on Grandstand Circle. Called Dev Tech Kim to verify no sidewalk. She checked plot and plat plans and agreed, no sidewalk on Grandstand Circle. Contractor is going to check with developer on adding the sidewalk and how to proceeded on designing the ADA ramp. RP 6-9-21

Comments: