

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210348
Address: 2930 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Partial	Thursday, June 10, 2021

Informational:

1 Misc

-EXTERIOR PORTAL FRAMING AND DECK TRUSSES OK TO COVER

-INTERIOR AT PFH: PROVIDE TWO ROWS 16D SINKER NAILS 3' OC AT TOP PLATE TO HEADER-CHECK ON ALL ROUGH

Comments: