

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20200776
Address: 114 SE DOUGLAS ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Joe Starlin	Partial	Friday, June 11, 2021

Informational:

1	Misc	5-11-21 9:16am The silt fence needs to be put back up along Douglas. There is water with silt leaving the site at the bottom of Main St. Main St. Is covered in dirt and debris and it is raining lightly. I have left a voice and text message with the superintendent of the site about the erosion issues. 6-11-21 8:12am I spoke with Cityscape about cleaning Main St. And to put gutter buddy's across the road. Rain is expected today.
---	------	---

Comments: