

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20203953
Address: 4400 SW TANZANITE CIR, LEES SUMMIT, MO 64082
Inspected On: Friday, June 11, 2021
Inspected By: Robb Popp
Expiration Date: 7/2/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Temporary C of O	Friday, June 11, 2021

Corrective Action Required:

1 Misc **TCO UNTIL 7-2

-MAINTAIN EROSION CONTROL UNTIL SOD IS IN PLACE-CLEAN
STREETS AND SIDEWALK OF DEBRIS, PROVIDE EROSION CONTROL TO
PROTECT SIDEWALK

-Final grade and sod
-Splash blocks at all downspout and sump pump discharge
locations, min 36" from foundation