

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20210103  
Address: 2100 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer Construction Inspection</b>	John Jackson	Partial	Thursday, June 10, 2021

Informational:

1 Misc

6/10/21 Thursday

Contractor Beemer cut into the steel encasement ( that crosses Town Center Drive ) as approved by City engineer over project. The contractor had to modify encasement to get the necessary clearance from exist manhole.

6/11/21 Friday

Contractor removed steel encasement and reassembled the encasement protective covering. Contractor is trying to get approval to tap 12" sanitary main.

**Comments:**