

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204843  
Address: 129 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Ronald Paynter	Passed	Friday, June 11, 2021

Informational:	
1 Misc	Forms were placed and aggregate was present and compacted. RP 6-4-21
Informational:	
2 Misc	Finished driveway meets LS specs. RP 6-11-21

**Comments:**