

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204449
Address: 114 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Michael Harkins	Failed	Friday, June 11, 2021

Corrective Action Required:

1	Misc	PROVIDE AS GRADED PLOT PLAN PROVIDE FINAL GRADE, SOD, SPLASH BLOCKS PROVIDE LAWN IRRIGATION PERMIT PROVIDE GUARDRAIL FRONT STOOP OVER 30" TO GRADE ADDRESS FULL HEIGHT CONTINUOUS 6x6 CEDAR POST DECK PROVIDE THROUGH-BOLTS DECK BEAM TO POST PROVIDE SUMP DISCHARGE 36" FROM FOUNDATION PROVIDE 6" WOOD SIDING TO FINISHED GRADE SEAL TOP OF METER CAN & AC DISCONNECT SEAL EXTERIOR LOW VOLT PENETRATIONS NEAR METER CAN SEAL EXTERIOR LIGHT FIXTURES GARAGE
---	------	--

Comments: