

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20210599  
Address: 2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Commercial Curb Inspection</b>	Joe Starlin	Partial	Friday, June 11, 2021

Informational:

1 Misc

6-11-21 8:28am Bedrock Concrete are pouring curb. They did not cure the back side of the curb and only had a light coat on the front. I had them re-cure front and back. 10:19am They are on the south side of the site and finishing up with curb. They will setting up the hand pours on Monday the 14th.

**Comments:**