



PLANS REVIEW CONDITIONS

Permit No: PRCOM20203513 Date: June 14, 2021
Project Title: LSR7 - LSHS - 2020 ATHLETIC COMPLEX IMPROVEMENTS Applicant:
Location: PROGRESSIVE ELECTRONICS INC
400 SE BLUE PKWY, LEES SUMMIT, MO 64063 6102 ARLINGTON AVE
Type of Work: RAYTOWN, MO 64133
Occupancy Group: A-5
Description: CONSTRUCTION OF NEW RESTROOMS CONCESSIONS, TICKET BOOTHS AND BLEACHERS
Construction Type: Type IIB (Unprotected) Primary: (816) 765-5750
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.