

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210837
Address: 2038 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Partial	Monday, June 14, 2021

Informational:
1 Misc

GARAGE PFH PORTAL FRAME
HOLDDOWNS & 3" O.C. NAILING APPROVED
OK TO COVER

PROVIDE 2 ROWS 16D SINKER 3" O.C. TOP PLATE TO HEADER
5/8 ANCHOR SHALL BE IN MIDDLE 1/3 THE WIDTH OF PLATE
CHECK ABOVE ON ROUGH IN

Comments: