

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201715  
Address: 3129 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Deck Final Inspection - Residential</b>	Robb Popp	Failed	Monday, June 14, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide Simpson end post caps and post bases per option 2 of detail 5 on S1.3 or continous posts with let in beam and through bolts per option 1
---	--------------------------	--

**Comments:**