

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20191614  
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Monday, June 14, 2021

Informational:  
1 THIRD FLOOR

— AREAS APPROVED —

\*\*\*BUILDING C\*\*\*

ROOMS: 3019-3031  
-STAIRWELL WALLS AND CEILING  
CORRIDOR TO SHAFT WALL  
SOFFIT FRAMING IN CORRIDOR

\*\*\*BUILDING B\*\*\*

CORRIDOR TO SHAFT WALL  
ROOMS: 3003-3016  
STAIRWELL WALLS AND CEILING  
SOFFIT FRAMING IN CORRIDOR  
STAIRWELL WALLS AND CEILING

\*\*\*BUILDING A\*\*\*

ROOMS: 3001, 3002, 3017, 3018, 3037, 3038, 3039, 3041, 3042, 3043, 3044, 3045, 3047  
CORRIDOR TO SHAFT WALL

## STAIRWELL WALLS AND CEILING

### Informational:

2 SECOND FLOOR

—AREAS APPROVED—

\*\*\*BUILDING C\*\*\*

ROOMS: 2019-2031  
CORRIDOR WALLS AND CEILING  
STAIRWELL WALLS AND CEILING

\*\*\*BUILDING B\*\*\*

ROOMS: 2003-2017  
CORRIDOR WALLS AND CEILINGS \line STAIRWELL WALLS AND CEILING

\*\*\*BUILDING A\*\*\*  
CORRIDOR CEILINGS TO SHAFT WALL  
ROOMS: 2001,2002, 2017,2018,2040-2045  
STAIRWELL WALLS AND CEILING

### Informational:

3 FIRST FLOOR

—AREAS APPROVED—

\*\*\*BUILDING C\*\*\*  
CORRIDOR CEILINGS TO SHAFT WALL  
ROOMS:1015,1017,1020-1030  
STAIRWELL WALLS AND CEILING

\*\*\*BUILDING B\*\*\*  
CORRIDOR CEILINGS TO SHAFT WALL  
ROOMS: 1002-1015  
STAIRWELL WALLS AND CEILING

\*\*\*BUILDING A\*\*\*  
CORRIDOR CEILING TO SHAFT WALL  
EXTERIOR WALL 1032 OK TO INSULATE  
STAIRWELL WALLS AND CEILING

\*\*MCAL BUILDING\*\*  
PRE ROCK:  
MECHANICAL ROOM 165 NORTH WALL  
ROOM 1057 OK TO ROCK FOR ELECTRICAL GEAR EAST AND SOUTH WALLS  
STAIRWELL WALLS AND CEILING  
ROOMS 1018, 1061

### Corrective Action Required:

4 Miscellaneous  
Correction

-EXPOSE AND SEAL PENETRATIONS AT SHAFT WALL PER UL LISTING

\*\*\*5-28\*\*\*  
2035A- FLASH OPENINGS

2047-NOT INSPECTED

3047- COMPLETE MECHANICAL VENT/ DRAIN

\*\*\*6-4\*\*

-SHAFT PENETRATION PER UL AT 1002 MECHANICAL CLOSET

**Comments:**