

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20211884  
Address: 350 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                      | Inspector:  | Outcome: | Date:                 |
|----------------------------------|-------------|----------|-----------------------|
| <b>Rated Assembly Inspection</b> | John Morris | Partial  | Monday, June 14, 2021 |

Informational:

1 Misc

Partial approval of rated assembly between occupancies.  
-Srew pattern approved on 340 side of assembly except in front office area where window was removed.  
-Screw pattern approved on 350 side of assembly  
-complete fireblocking at roof deck and at all through/membrane penetrations of assembly

**Comments:**