

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20203936  
Address: 2926 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Tuesday, June 15, 2021

Corrective Action Required:

1	Misc	-clean all mud front street at front of lot -Obtain lawn irrigation system permit -Complete sod front of lot -Sod less than 6" from siding, see back west side of house -set sewer tracer box to grade
---	------	--

**\*\*OK FOR TCO - TCO EXPIRES 6/24/21\*\***

**Comments:**