

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211961
Address: 1523 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Robb Popp	Passed	Thursday, June 10, 2021

Corrective Action Required:

1	Misc	PREVIOUS INSPECTION PASSED IN ERROR -CONTRACTOR CALLED TO CANCEL-
---	------	--

Corrective Action Required:

2	Miscellaneous Correction	-POST SITE ADDRESS
---	-----------------------------	--------------------

Comments: