

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210529
Address: 3219 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Residential	John Morris	Failed	Wednesday, June 16, 2021

Corrective Action Required:

1	Misc	-install reinforcement per concrete header detail, foundation opening under suspended slab -provide engineer documentation for retaining wall exceeding 4' in height
---	------	---

Comments: